




WILLMAR MUNICIPAL UTILITIES


February 2019 Wind Turbine Report

"Willmar Municipal Utilities will provide safe, reliable & quality utility services at competitive rates for their customers."



	Production (KWH)		Availability (%)		Total KWH	Major Outages
	#3	#4	#3	#4		
Feb. 2019	237,229	246,933	96.8	99.9	484,162	
Jan. 2019	329,634	295,250	94.2	88.6	624,884	
Dec. 2018	316,836	270,427	99.8	97.2	587,263	
Nov. 2018	312,989	315,427	99.0	100.0	628,416	
Oct. 2018	195,545	310,361	69.7	90.6	505,906	#3 and #4 Blade Repairs
Sept. 2018	263,800	281,669	97.2	97.8	545,469	
Aug. 2018	137,091	141,560	100.0	81.6	278,651	
July 2018	155,457	175,099	95.2	98.2	330,556	
June 2018	249,292	274,114	90.4	91.3	523,406	
May 2018	209,088	218,131	94.6	96.9	427,219	
Apr. 2018	303,979	377,047	78.6	100.0	681,026	
Mar. 2018	389,456	42,709	93.6	6.9	432,165	#4 Blade Pitch Control Unit Failure
Feb. 2018	317,618	-	99.6	0.0	317,618	#4 Blade Pitch Control Unit Failure
2019 Total	566,863	542,183			1,109,046	

Month	2015	2016	2017	2018	2019
January	720369	393,477	534,867	398,844	624,884
February	695143	740,655	771,227	317,618	484,162
March	746045	761,028	806,936	432,165	
April	965530	1,041,382	601,823	681,026	
May	755889	557,947	598,108	427,219	
June	324005	583,043	534,662	523,406	
July	755889	199,043	214,304	330,556	
August	457386	321,326	109,215	278,651	
September	499215	609,004	400,210	545,469	
October	744572	727,379	925,000	505,906	
November	929609	640,522	690,847	628,416	
December	616700	998,977	338,980	587,263	
Total	8,210,352	7,573,783	6,526,179	5,656,539	1,109,046



Fun Fact - Because the generator is connected by an electrical cable that runs from the nacelle (top) to the switch gear (bottom), the turbine has the potential to wrap itself up and needs to periodically stop and unwind or rotate in the opposing direction in order to avoid tangling.